



# **THE ADMINISTRATION OF UNION TERRITORY OF LADAKH**

## **OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH**

(e-mail-igp-ladakh@police.ladakh.gov.in)

(Office Phone No: 01982-260888)

No: PHQ/ Dir/F&ES/UTL/2021-1342-43

Dated: 21/04/2021

**Subject: Fire NOC in favour of Kendriya Vidyalaya at Trespone, Kargil.**

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the school building which has been done by I/C Fire and Emergency Services, Kargil. The detailed report is as under is as under:

### **Location/ Accessibility:**

The School is constructed at Trespone, Kargil. It is located at Longitude 76.029084 and Latitude 34.422021. The site is approximately 21 Kms away from Fire and Emergency Services Station, Kargil. It takes approximately 42 minutes to reach the site which is approachable for fire appliances.

### **Detail of building:**

The school building have 02 blocks. Both the blocks are connected with each other. The detail of the blocks is as under:

**1<sup>st</sup> block:** It is two storied school building having two stair cases and one ramp. In the ground floor there is Principal office, medical room and 07 class rooms. There is one window in each class room. The size of the window is 8'6"x5'6". Two side of the windows have provision to open. There are 04 exits doors.

1<sup>st</sup> floor have 07 class rooms.

**2<sup>nd</sup> Block:** It is two storied building having two stair cases. In the ground floor there is Library, Chemistry laboratory, Physics laboratory, Biology laboratory, Math laboratory and two store rooms. There are 20 windows and the size of each is 8'6"x5'6". The two side of windows have provision to open. 1<sup>st</sup> floor have Computer room, music room, drawing room, activity room and 05 class rooms.


There are 450 students and 24 staff members.

### **The following Fire Safety equipment's found installed in School Building:**

01. 20 no's of ABC type fire extinguishers 5 kg capacity and 02 nos CO2 type fire extinguishers 4.5 kg capacity found installed in the school building.
02. 04 no's of plastic tanks 1000 liters capacity each found installed in the school premises.
03. 01 no's of Submersible bore, fitted with high rated pump found installed in the school premises.

04. The main gate size is 15 feet. It is sufficient for the Fire tender to enter the school premises in case of emergency.

**FIRE NOC is given in favour of Kendriya Vidyalaya at Trespone, Kargil** for a period of **One year** from the issuance of this letter provided the School management placed 9 number of sand bucket and constructs 20 thousand underground water tank before opening the school after it is allowed to open keeping in view the COVID situation.

  
Director, F&ES, Ladakh  
PHQ, Agaling, Leh

**Copy to:**

01. Principal, Kendriya Vidyalaya Trespone, Kargil for information and n/a.
02. Superintendent of Police F&ES, Ladakh for information and with the direction to detail IC F&ES Kargil to ensure placement of 9 number of sand bucket and construction of 20 thousand litres of underground water tank in a time bound manner.
03. Office file

